

FIRE PROTECTION

- ☐ Is your local fire department well acquainted with your facilities, its location and specific hazards? If not, contact the Honolulu Fire Department's Fire Prevention Bureau at 831-7764 or 831-7765 to schedule an inspection.

Action to be Taken

Assigned To:

- ☐ If you have a fire alarm system, has it been accepted by the local fire department as required?

Action to be Taken

Assigned To:

- ☐ If you have a fire alarm system, is it tested at least annually?

Action to be Taken

Assigned To:

- ☐ If you have interior standpipes and valves, are they inspected regularly and tested by a certified private fire protection company every five years?

Action to be Taken

Assigned To:

- ☐ If you have outside private fire hydrants, are they flushed at least once a year and on a routine preventative maintenance schedule in accordance with the county water requirements?

Action to be Taken

Assigned To:

- ☐ Are fire doors and shutters in good operating condition?

Action to be Taken

Assigned To:

- ☐ Are fire doors and shutters unobstructed and protected against obstructions, including their counterweights?

Action to be Taken

Assigned To:

- ☐ Are fire door and shutter fusible links in place?

Action to be Taken

Assigned To:

Fire Protection

- ☐ Are automatic sprinkler system water control valves, air and water pressure checked periodically? If the system has more than one hundred sprinkler heads, is it monitored? (required on the island of Oahu)

Action to be Taken

Assigned To:

- ☐ Is the maintenance of automatic sprinkler systems assigned to a certified private fire protection company and inspected as well as tested at least annually?

Action to be Taken

Assigned To:

- ☐ Are sprinkler heads protected by metal guards, when exposed to physical damage?

Action to be Taken

Assigned To:

- ☐ Is a 24" clearance maintained below sprinkler heads?

Action to be Taken

Assigned To:

- ☐ Are portable fire extinguishers provided in adequate number and type in accordance with National Fire Protection 10 – Standard for Portable Fire Extinguishers?

Action to be Taken

Assigned To:

- ☐ Are fire extinguishers mounted in readily accessible locations? Mounted not more than 5' above the floor with the bottom of the extinguisher located no less than 4" above the floor?

Action to be Taken

Assigned To:

- ☐ Are fire extinguishers annually re-inspected and tagged by a certified private fire protection company?

Action to be Taken

Assigned To:

- ☐ Are employees periodically instructed in the use of extinguishers (P.A.S.S.) and fire protection procedures?

Action to be Taken

Assigned To:
